



New Standards for Plumbing Fittings and Fixtures and their Trigger Dates

Regulated water appliances in California under Title 20	Previous CA Title 20 Regulation	Effective date for this standard is September 1, 2015	Effective date for this standard is January 1, 2016	Effective date for this Standard is July 1, 2016	Effective date for this standard is July 1, 2018	Comment
Showerhead	2.5 gpm at 80 psi			2.0 gpm at 80 psi	1.8 gpm at 80 psi	New tiered regulation
Lavatory Faucet and aerator	2.2 gpm at 60 psi	1.5 gpm at 60 psi		1.2 gpm at 60 psi		New tiered regulation
Public Lavatory Faucet	2.2 gpm at 60 psi		0.5 gpm at 60 psi			New regulation. No sell through is permitted after January 1, 2016.
Kitchen (Sink) Faucet	2.2 gpm at 60 psi		1.8 gpm, optional temporary flow of 2.2 gpm, at 60 psi			New regulation; no sell through is permitted after January 1, 2016
Non Wall Mount Urinal	0.5 gpf max		0.5 gpf max			CEC standard catch up to CA Health and Safety Code standard
Wall Mounted Urinal	0.5 gfp max		0.125 gpf max			New regulation; no sell through permitted after January 1, 2016
Water Closet (Toilet)	1.28 gpf max		1.28 gpf max			CEC standard catch up to CHSC standard; no sell through permitted. Water closets sold or offered for sales on or after January 1, 2015, shall pass the Waste Extraction Test (Section 7.10) of ASME A112.19.2